

Expert Statement 655 31941/4e* dated 18 December 2006

referring to Evidence of Performance 601 31941/4
dated 04 December 2006

**Fogging test of inserts incorporated into
the cavity width of insulating glass units**



* Translation of Expert Statement 655 31941/4 dated 4 December 2006

Client **Pellini S.p.A.**
Via Fusari, 19

26845 Codogno (Lo)
Italy

Basis

EN 1279-6 : 2002-07;
Glass in building - Insulating
glass units - Part 6: Factory
production control and periodic
tests, Annex C, Fogging test
Test report 601 31941/4 dated
04 December 2006

Product	Insulating glass unit with shading device
Designation	ScreenLine [®] SL20C
Overall dimensions (W x H)	350 mm x 500 mm
Configuration in mm	4 TSG / 20 / 4 TSG
Spacers	Aluminium, by Erbslöh
Building element in cavity width	Moving shading device with magnetic frontal control venetian blind clipper

Instructions for use

The original test report is in-
tended to demonstrate the fog-
ging of inserts incorporated into
the cavity width of insulating
glass units.

Validity

The expert statement referring
to demonstrate the fogging of
inserts incorporated into the
cavity width of insulating glass
units does not allow any state-
ment to be made on any further
characteristics of the construc-
tion submitted regarding per-
formance and quality.

Validity of the expert statement
expires with expiry of any one
of the above items referred to
as basis (standards or test re-
ports).



The insulating glass unit fulfils the requirements of DIN EN 1279-6, Annex C*)

*) based on Test Report 601 31941/4 and on the Manufacturer's
Declaration with reference to the configuration of the materials
used and the processing of the insulating glass units

Notes on publication

The **ift** Guidance Sheet „Guid-
ance on the use of **ift** test re-
ports" applies.

The cover sheet can be used
as an abstract.

Contents

The report comprises a total of
2 pages.

Expert Statement

- 1 Order
- 2 Basis
- 3 Results and statement

ift Rosenheim
18 December 2006

Karin Lieb, Dipl.-Ing. (FH)
Head of Testing Department
ift Centre Glass, Building Materials & Building
Physics

Irina Hausstetter, Dipl.-Ing. (FH)
Test Engineer
ift Centre Glass, Building Materials & Building
Physics